



Addendum # 1



Date: April 24, 2024
To: All bidders
From: Louis Joseph, Buyer
Solicitation Number: ITB# CDS/230677
Solicitation Title: **Roof Replacement - Munnerlyn**

SOLICITATION ADDITIONS, CLARIFICATIONS, AND CORRECTIONS

NOTE: ALL INSTALLATIONS OR REPLACEMENTS MUST INCLUDE NEW PRODUCTS OR MATERIALS.

ITEM 1

1. The Screws shall be WoodZac Lifetime Warranty Panel Screws equal/better.
2. The metal should overhang the fascia enough so that water does not siphon backward which may cause damage to the home. (min 2" without gutters).
3. The color shall be **hunter green**, please submit it for approval before ordering.