



# Addendum # 1



**Date:** April 24, 2024  
**To:** All bidders  
**From:** Louis Joseph, Buyer  
**Solicitation Number:** ITB# CDS/240288A  
**Solicitation Title:** **HVAC Replacement - Franklin**

## SOLICITATION ADDITIONS, CLARIFICATIONS, AND CORRECTIONS

**NOTE: ALL INSTALLATIONS OR REPLACEMENTS MUST INCLUDE NEW PRODUCTS OR MATERIALS.**

### ITEM 1 HVAC

3. The condenser unit shall be installed on a heavy-duty aluminum stand. The condenser shall be secured to stand. The stand shall be secured to the pad.
7. The new HVAC system shall be 16 SEER/SEER2