



# Addendum # 1



**Date:** November 17, 2022  
**To:** All bidders  
**From:** Louis Joseph, Buyer  
**Solicitation Number:** ITB# CDS/220676  
**Solicitation Title:** Burke Residential Rehabilitation

## EXHIBIT B - WORK WRITE-UP ITEM 4 - Plumbing

**Add:**

1. Replace hose with bib leaking.

## EXHIBIT B - WORK WRITE-UP ITEM 8 – Interior Repair

**Clarification:**

1. Flooring where there is asbestos must be replaced; Per asbestos report.
2. Ceilings must be repaired as per the work write-up.

## EXHIBIT B - WORK WRITE-UP ITEM 9 - Electrical

**Add:**

1. Install a chase to cover the wiring above the panel.
2. Re-wire the water heater into a protective conduit.
3. Install GFCI protections where code is required.
4. Make sure that the dryer receptacle is moved a minimum of 3' from the electrical panel.
5. All receptacles must be installed behind the washer of the carport.